

## All Questions Received for RFP 17-003

### Questions 7-3-17

I would like to Request for a copy of the Plans and Specs of Road Repair and Rip Rap Installation Project.

Answered 7-3-17. It is on the Village Website [www.corralesnm.gov](http://www.corralesnm.gov)

I would like to request a copy of the Plan Holder's List as well. There is no plan holders list.

Is this bidding on 07/25/2017 at 4:00 PM? The Bid for the RFP must be into the Village of Corrales at 4324 Corrales Road, Corrales NM by 4:00 pm July 25, 2017 to be eligible for review.

Is the Mandatory Pre-bid meeting on 07/11/2017 at 10:00 AM? Yes the Mandatory pre-bid meeting is 07/11/2017 at 10:00 AM

Are you having an engineer or architect as a design team? No, it is a grading and base course placing on an existing road after flood damage.

May I ask the estimated cost/budget? This is an RFP to get prices to complete the work and the prices are used as part of the scoring of the RFP.

Any addendum issued as of the moment? No addendums have been issued as of this date

Is there a Plan Deposit? There are no plans.

Do you have union requirements on all your projects? No, there are not union requirements. However, there is a Public Works Minimum Wage Act in New Mexico information can be found at <https://www.dws.state.nm.us/Labor-Relations/Labor-Information/Public-Works>

### Questions 7-3-17

I just want to ask if you have union requirements on all your projects? No, there are not union requirements. However, there is a Public Works Minimum Wage Act in New Mexico information can be found at <https://www.dws.state.nm.us/Labor-Relations/Labor-Information/Public-Works>

May I ask the estimated cost/budget of this project?

This is an RFP to get prices to complete the work and the prices are used as part of the scoring of the RFP.

### Questions from mandatory pre- bid meeting 7-11-17

You need to put a unit price in for each item requested in Appendix E however your total Bid should be listed with the maximum amount of rip rap at 74 cubic Yards. The actual amount needed will be determine with the issuance of the contract.

What color base course is required? There is no color specification. However, the base course will be DOT type II non- recycled base course. A copy of the laboratory report on the base course will be required.

What are the road's boundaries? The road will be in current location. The road runs from the telephone pole to the south. There will be no displacement of landscaping or other personnel property.

What way does the road drain? The road will drain to the south from the west end of the road to the speed limit sign at the east end of the road pointed out while on the RFP pre-bid meeting.

Is there drainage ditch on the side of the road to be installed? There is no ditch installation only a small swale to be put on drainage side.

### All Questions Received for RFP 17-003

How wide is the rip rap? The rip rap will be 2' wide never making the road smaller than 12" Locations will be marked on award of the contract.

Is there fabric under the rip rap? No there will not be fabric under the rip rap.

Will surveying be required for the slope or will grading with the level work? No survey required, grading with a level will work. The road needs to slope from west to east without humps or low spots. Material from the existing road can be used and if more is needed the Village has it for use.

Will line spots be needed? Yes you will need to request line spots.

Will dedicated flaggers be needed? Yes, this is a very narrow road and flaggers will be needed to ensure safety.

Can we use vacant lot for turn around and staging while working? The Village will check with property owner and let each bidder know the decision.

Can we stage and leave equipment in the cul-d-sac? No the cul-d-sac cannot have equipment after work hours.

Where can we stage? 2200 Loma Larga, no blockage of the water tank is allowed. Water can be used from the but a record of gallons used will be submitted to the Village .

#### Question 7-17-17

Is basalt allowable for Riprap? Yes basalt is allowable as long as it meets the size requirements in the RFP.